

Architectural Specification

Nordock CONSTRUCTOR™ Series - Model CM Mechanical Docklevelers

Available Capacities: Available Widths: Available Lengths (Nominal):		dths: 6', & 7'
		SECTION 11161 DOCKLEVELERS
PART	1 - GE	NERAL
1.01	WOR	K INCLUDED
	A.	Factory assembled dockleveler with subframe, crossover lip, retractable deck stops, and working range side guards.
	B.	Curb angles or pour-in-pan assembly.
	C.	Installation and Owner's Manual.
1.02	RELATED WORK	
	A.	Section 11160 - Truck Restraints.
	B.	Section 11164 - Seals and Shelters.
	C.	Section 11165 - Dock Bumpers.
1.03	REFE	RENCES
	A.	ANSI/ASME MH 14.1 1987, "Loading Dock Levelers and Dockboards."
1.04	SYST	EM DESCRIPTION
	A.	Hinged lip, mechanical, recessed dockleveler to the following requirements:
		1. Nominal Size: () wide x () long.
		2. Capacity: () lbs. per ANSI/ASME MH 14.1 1987.
		 Service Range: Twelve inches above dock level and Twelve inches below dock level.
		4. Lip projection: 11 inches beyond front face of standard 4" bumpers with a

16" long lip.

1.05 SUBMITTALS

- A. Submit Manufacturer's installation instructions.
- B. Submit shop drawings showing pit construction and dimensions.

PART 2 PRODUCTS

2.01 ACCEPTABLE MANUFACTURERS

A. CONSTRUCTOR™ Series - Model CM (_____) as manufactured by Nordock Inc.

2.02 EQUIPMENT

- A. Curb angles (Optional): 8-piece 3 x 3 x 3/16 inch angle iron with concrete anchors to cover all pit edges.
- B. Pour-In-Pan (Optional): 6-piece angle iron frame with concrete anchors and fully enclosed steel pan on sides back and bottom. Dockleveler to be pre-installed in pan.

C. Dockleveler:

- 1. Ramp: 50-55,000 psi-yield steel tread plate, reinforced with 50,000 psi-yield steel beams. Beams to be formed channel type 6" high with 2" top and bottom flanges for additional plate support. Unitized welded ramp to allow side-to-side tilt to follow uneven truck beds. Six rear hinge connection supports with full width hinge rod. Lip hinge tubes and header plate to beam connections to be continuously welded. Front and rear hinge rods to be zinc coated SAE 1045 factory coated with anti-seize lubricant. Working range side guards to be welded to deck for structural support.
- 2. Lip: 50-55,000-psi yield tread plate. Superior DOM hinge tubes to be continuously welded to lip plate. Plate to be full width of deck, non-tapered with leading edge chamfer to be milled at maximum 15 degrees.
- 3. Subframe: Welded assembly to have a rear structural angle welded to hinge tubes and minimum six solid steel rear supports with connections to the longitudinal members. Front center section to be open for easy pit cleaning. Security night lock to prevent illegal entry to the building when the dock leveler is stored and the door is closed.
- 4. Mechanical System: Ramp to be spring counter-balanced and raise when the integral holdown is released. The lip to extend automatically into the truck as the ramp is walked down. Ramp shall be free to float with the up and down movement of the truck at all times. Lip must unlock on contact with the truck bed or at full lowered position allowing it to retract behind bumpers when not engaging a truck bed. Heavy duty lifting springs constructed from superior chromium silicon and factory finish painted.

5. Finish: All surfaces to be degreased and painted with high solid machinery enamel. Provide standard manufacturer's color.

2.03 OPTIONS

- A. 18" or 20" long lip.
- B. Side or side and rear brush weather seals.
- C. Full range telescoping side guards.

PART 3 EXECUTION

3.01 PREPARATION

- A. Provide curb angles for setting pit edges. (Optional)
- B. Provide dock leveler in pour-in-pan for setting in place. (Optional)

3.02 INSTALLATION

- A. Install in prepared pit in accordance with manufacturer's instructions.
- B. Adjust installed unit for operation as specified by Manufacturer.